



NOTES:

1. REDUCED PRESSURE PRINCIPLE ASSEMBLIES (RP) MUST CONFORM TO COG SPECIFICATIONS. REFER TO COG APPROVED LIST OF BPA'S.
2. COG APPROVED RP INCLUDES SHUT-OFF VALVES #1 AND #2 AS PART OF THE ASSEMBLY. NO SUBSTITUTIONS SHALL BE PERMITTED.
3. TEST COCK #1 SHALL BE UPSTREAM OF SHUT-OFF VALVE #1 AND IS PART OF THE APPROVED ASSEMBLY.
4. PIPE MATERIAL AND FITTINGS SHALL BE AS SPECIFIED IN COG STANDARDS & SPECIFICATIONS.
5. INSULATED ENCLOSURE SHALL BE AS SPECIFIED IN COG ENCLOSURE INFORMATION.
6. ALL LOCATIONS FOR BPA'S REQUIRE COG APPROVAL.
7. THERE SHALL BE NO TAPS, PIPING BRANCHES, UNAPPROVED BYPASS PIPING, HYDRANTS, FIRE DEPT. CONNECTION POINTS, OR OTHER WATER-USING APPURTENANCES CONNECTED TO THE SUPPLY LINE BETWEEN ANY WATER METER AND ITS COG-REQUIRED BACKFLOW PREVENTER.
8. EACH COG-REQUIRED BPA IS REQUIRED TO BE TESTED BY A COG-APPROVED CERTIFIED TESTER PRIOR TO PLACING THE WATER SYSTEM IN SERVICE.
9. SHUT OFF VALVE REQUIRED BETWEEN METER AND BPA TO ALLOW REMOVAL OR SERVICE WITHOUT TURNING OFF METER.

REVISED	F.B.	PG.	DATE: JUNE 10, 2003	STANDARD DETAIL REDUCED PRESSURE PRINCIPAL ASSEMBLY (RP) 3/4"-2" ABOVE GROUND	OFFICE OF THE CITY ENGINEER GASTONIA, N.C.
			SCALE: NONE		FILE NO. 71B-30
			DRAWN BY: TAJ		
			CHECKED BY: MWB		
			CITY ENGINEER: FAP		