Yellow indicates interim approval subject to change Red text indicates new addition

Transition

Couplings

AC to DIP

Tapping Sleeve

& Valve

Stainless Steel Tapping

Sleeve

Fittings

Hymax

Viking Johnson

Smith Blair

M & H Valve & Fitting

American Flow Control

Kennedy

Mueller

Clow

Romac

Mueller American Pipe

Trim Type

Tyler

Union Foundry

Star Pipe

US Pipe

PROJECT #

Still need submittal for these each

time. Must Verify pipe OD before

See CMUD Spec

Size on size not allowed.

ordering.

Section 14.08

Section 14.09

The materials, parts and appurtenances contained within this document are "pre-approved" for use within the City of Gastonia for the project listed below.

Please "Check" desid	*Shop drawings for all "tap" material (water	this project. Any materials not contained within & sewer) must be included with submittal package	e for Utility Departm						
All materials must be manufactured and tested in USA City of Gastonia - Land Development Pre-Approved Materials List - January 2024									
Project:	••	Date Su	bmitted:						
Contractor:		Material	Material Supplier:						
Owner/Developer:									
		WATER MATERIALS							
Material / Part	Item Manufacturer	Model #	City Detail Specification	NOTES					
	North American Pipe	-	Section 14.04						
	Diamond Plastics	4		6"-10": C-900, Minimum (DR 14)					
	J-M Pipe	-		Alternative must be approved by City					
PVC Pipe		C-900		2022 Interim Approval - 12" PVC C-900 (DR 14) - Marker Tape 18" above pipe. DIP required in encasements. DIP required for ARV's. DIP required for crossings.					
	National Pipe			2": Mimimum CL200 (SDR 21)					
Cement Lined DIP	American Pipe US Pipe McWane	CL 51, 52, 53, Cl 350 Mechanical Joint Push-on (Belltite, Fastite, or Tyton) Restrained Joint (MECH-LOK)	Section 14.06	AWWA C-151/ANSI STD # A21-51 or latest revision. Zinc outside coating or standard asphaltic coating allowed.					
Cement Lined DIP - Interim Approval		TR Flex		Not for use in encasements. No field welds allowed. Installed as per mfg recommendations. TR Flex fittings not allowed. Approved on a case by case basis.					
	Mueller	A-2380-20, Super Seal, A-2360	Section 14.07						
Gate Valve	M & H Valve & Fitting	Style 67-01							
	American Flow Control	#55, Series 500NRS, 2500 Series	_	MJ x MJ					
	Kennedy	571X	4	2" square nut					
	Jenkins Brothers	370 (up to 2") threaded bronze	4	Open CCW (left)					
	Grinnell	3050 (up to 2") threaded bronze C-500	-	AWWA C-509 or latest revision					
	Hydra Gate Metroseal	C-500 C-509	-						
	Clow	F-6100, F-5065	-						
Resilient Seated Wedge Valve	Clow	F-6100 MJ	Section 14.07	MJ x MJ					
	American Flow Control	500 NRS MJ, 2500 Series		2" square nut					
	Mueller	A-2361	1	Open CCW (left)					
	Kennedy	1571X, 757155	1	AWWA C-509, 515 or latest revision					
Fire Hydrant	American Flow	Mark-73-5	Section 14.11	Open CW (right) with direction arrow. Ci					
	Mueller	Super Centurion 20, A421 Centurion	Detail 71B-7	Spec threads and paint. 1 1/4" operating					
	Kennedy	Gurardian K-81-A, K-81-D	Detail 71B-8	nut.					
	Clow	Medallion	1	not.					

Hymax 2

Maxistep

413, 421

Valve 751, Sleeve 1174, 1274

Valve 565, 2500, Sleeve 1004

950X H-667, H-619, H-615

Valve F-6114, F-5093, Sleeve F-5205, F-5207

SST Mueller H-304

C-153

C-110, C-153

C-153

C-153

C-110, C-153

C-110, C-153

Valve T-2360

		W	ATER MATERIALS CONTINUED		
Material / Part	Item	Manufacturer	Model #	City Detail	NOTES
		EBAA	1100 Series	Section 14.09	
		Uniflang Smith Blair	1400 Series CamLock 111/120	-	
		Ford	1400D		
Restraint		Star Pipe	Stargrip Series 3000 DIP		
Restraint		Sigma	One-Lok Series D-SLDE		DIP Pipe
		EBAA Romac	1700 Series 611	Old Spec	DIP Interim Approval - 2022 PVC Interim Approval - 2022
		EBAA	Series 1600		PVC Interim Approval - 2022
		Tyler Union	TufGrip Series 1000 DIP & 2000 PVC		
Push on Joint Restraint		US Pipe	Field Lok 350	Section 9.06	Not for use in encasements. Installed
Gaskets for DIP Interim Approval (4" - 12")		American McWane	Fast-Grip Sure Stop 350		as per manufacturer recommendations.
		Bingham & Taylor	4908 Series	Section 14.10	Slip type only, cast iron 5 1/4" shaft with
Valve Boxes		Charlotte Pipe & Foundry	UTL 274	-	appropriate cover and flange footing (all
		Tyler/Union	6855 Series		riser sections must be DIP).
Tracer wire				Section 14.04	14 gauge solid copper (uncoated)
Air Release Valve		Crispin	1 ": P-10, PL-10	Section 14.20	
(water main)			2 ": P-20, PL-20	Detail 71B-17	AWWA/ANSI C-105/A21.5
Polyethylene Encasement				Section 14.06	Tubes only. Minimum 8 mil. thickness.
				Section 13.23	
Steel Encasement Pipe		Empire Pipe & Supply			ASTM-A139, Grade B, AWWA C-200, Mimimum 0.25" thickness.
		Spider Manufacturing		Detail 71B-25	
Casing Spacers		Valaint Steel Cascade			
Casing Spacers		BWM Company			
		RACI Spacers North America			
Valve Box Procector Ring		Masonry Supply		Detail 71B-7	Must have wire reinforcement/rebar.
		Georgia-Lina Precast, Inc.			
	Item		SEWER MATERIALS	City Detail	
Material / Part	Used	Manufacturer	Model #	Specification	NOTES
		Tindall Concrete-Spartanburg		Section 13.09	
		Old Castle (D&M) Charlotte Tru-Contour, Inc.		Detail 71B-4 Detail 71B-3	
		Metromont	-		HS-20 load rated. Minimum 6" base
		Material Supply - Charlotte			thickness. Drop manholes require
Precast Manhole		Foley Products Company	4' and 5' Diameter		monolithic drop pad. Eccentric cones
		Wellington Hamrick Precast Dellinger			and flat-slab-top (FST) by special permission only.
		Performance Precast			permission only.
		Precast Supply Company			
		Precast Construction Products			
		East Jordan Iron Works	V-1384, V-2384 (locking) MH-GRE-24	Section 13.15 Detail 71B-1	City logo where available.
MH Ring & Cover		Ennis US Foundry	USF 669 & KL cover	Detail / IB-1	City logo where available.
		Charlotte Pipe		Section 13.20	
		J-M Manufacturing		-	
PVC Pipe		Diamond Plastics	E	-	Cell Class 12454 or 12364 must be
		National Pipe LCP Plastics	Ever-Green	-	clearly marked on all pipe.
		Contech	Truss Pipe	1	
		American Pipe	CL 51, 52, 53. CL 350	Section 13.05	AWWA C-151/ANSI STD # A21-51 or latest revision. Zinc Outside Coating or standard asphaltic coating allowed.
Cement Lined DIP		US Pipe McWane	Mechanical Joint		
			Push-on (Belltite, Fastite, or Tyton) Restrained Joint (MECH-LOK)		
Air Release Valve		Crispin	US20B(L), S20B(L)		
(force main)		Kent Or al		Continue 40.00	
		Kent Seal Conseal	No. 2 CS-102, CS-202	Section 13.09	ASHTO M-198, Federal Specifications S
Butyl Rubber Sealant		RuVan	RV30		
		Press-Seal	Pro-Stik		
				Section 13.06	
MH Steps		M A Industries	PS-1, PS-1-45	Section 13.09 Detail 71B-2	
		PSX		Section 13.09	
MH Boot		Kor-N-Seal			ASTM C923
				0	
Steel Encasement Pipe		Empire Pipe & Supply		Section 13.23	ASTM-A139, Grade B, AWWA C-200, Mimimum 0.25" thickness.

		SE	WER MATERIALS CONTINUED		
Material / Part	Item Used	Manufacturer	Model #	City Detail Specification	NOTES
Casing Spacers		Spider Manufacturing Valaint Steel Cascade BWM Company RACI Spacers North America		Detail 71B-25	
Expansion Joint Coupling		Dresser Smith-Blair	Style 63 611	_	
DIP/PVC Transition Coupling		Harco GPK	Molded Transition Coupling Y79-00089G Y81-00089S		This is an interim Approval (November 2018) - May be revoked at any time.
MH Vent Pipe				Detail 71B-4a	
Traffic Bearing Cleanout Cap		US Foundry	7631	71B-19D	
Sewer Tap Protector Ring		Masonry Supply Georgia-Lina Precast, Inc.		Section 13.19 Detail 71B-19	Must have wire reinforcement/rebar.
			STORM DRAIN MATERIALS		
Material / Part	Item Used	Manufacturer	Model #	City Detail Specification	NOTES
CB Frame, Grate & Hood		US Foundry Ennis East Jordan / Vulcan	5181 frame, 6420 grate 840.03 Type C V-4066-2	Detail 71C-1 Detail 71C-2 Detail 71C-3	Grate must have "City of Gastonia" lettering.
CB Frame, Grate for Valley Curb		US Foundry EJIW	5298 Frame and 6298 Grate V4520		Only approved on a case by case basis - normally when a driveway cannot be avoided.
RCP		Johnson Rinker Mid-Atlantic Drainage, Inc Foley Products Company Smith Setzer		Section 11.04	Class III, Wall "B", Minimum 15" Diameter Pipe, Maximum 36" Diameter FES, ASTM C-76
Precast Catch Basins		Tru-Contour, Inc. Dellinger Wellington Hamrick Precast Performance Precast Rinker Materials Mid-Atlantic Drainage, Inc			Rectangular precored units only, 6" minimum wall thicknes, H-20 lids, All Pre- Cast boxes shall meet NCDOT requirements
Precast Headwall					SPECIAL APPROVAL REQUIRED
Polypropylene Pipe		ADS			See Standard Specifications - Interim Appvd
HDPE		ADS	N-12		See Standard Specifications - Interim Appvd